

MASSACHUSETTS DEP DIVISION OF WATER SUPPLY
 TRIHALOMETHANE REPORT

THM

PWS ID 4122000 PWS Name Hanover Water Dept. Town Hanover

Sample Location Hanover Fire Dept. #2

Lab Sample ID 8136

Date Collected 9/17/92 Routine

Collected By R. Sides Special explain below

Lab Name Oliveira Laboratories Lab Cert. # MA022

Sample: Ground _____ Surface _____ Active _____ Inactive _____

Notes _____

	Result µg/l	MCL µg/l	Detection Limit µg/l	Analytical Method	Date Analyzed
Bromoform	ND	--	0.5	501.1	7/22/92
Chloroform	54.8	--	0.5	501.1	7/22/92
Bromodichloro- methane	10.7	--	0.5	501.1	7/22/92
Dibromochloro- methane	1.00	--	0.5	501.1	7/2/292
Total Trihalomethanes	66.5	100.0	----	-----	-----

ND - Not Detected

Surrogate Recoveries, Duplicate and Spike Analyses, as required by EPA method:

Surrogate Recoveries (2-Bromo-1-chloropropane): 102 %

Duplicate Analysis RPD (s): 0.6 - 2.1 %

Spike Analysis Recoveries: 97 - 108 %

Laboratory Director Signature and Date *Patricia Oliveira* 9/26/92

Please mail TWO copies of this report to your regional DEP office within 30 days of receipt of results and no later than 10 days after the end of the reporting period.