

Trihalomethane Report

Data Check - Unsigned

PWS ID #: 4122000 City/Town: HANOVER
 PWS Name: HANOVER WATER DEPT
 Primary Lab MA Cert #: M-MA022 Primary Lab Name: ANALYTICAL BALANCE CORP

PWS Class: COM

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10383	925 CIRCUIT ST - FIRE STATION #3	RS	W. MILLS	3/18/2014	O		

Sample Comments: **Analysis Comments:** **Lab Sample ID:**
 146573101

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	9.5	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	6.6	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	12.4	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	11.2	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	39.7	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10385	70 PONDEROSA	RS	W. MILLS	3/18/2014	O		

Sample Comments: **Analysis Comments:** **Lab Sample ID:**
 146573102

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	14.0	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	6.3	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	14.6	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	16.1	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	51.0	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10387	2055 WASHINGTON ST - COMPUTER CENTER	RS	W. MILLS	3/18/2014	O		

Sample Comments: **Analysis Comments:** **Lab Sample ID:**
 146573103

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	8.0	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	3.2	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

Trihalomethane Report

CHLOROFORM	5.3	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	9.8	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	26.3	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP

Data Check - Unsigned

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10388	33 ROCKLAND ST - HANOVER FITNESS	RS	W. MILLS	3/18/2014	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

146573104

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	19.1	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	1.8	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	43.3	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	10.1	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	74.3	UG/L	0.5	EPA 524.2	3/20/2014	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 641283

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000
 PWS Name: HANOVER WATER DEPT

3/31/2014 1:47:23 PM

Page 2 of 2

Trihalomethane Report

Data Check - Unsigned

PWS ID #: 4122000 City/Town: HANOVER
 PWS Name: HANOVER WATER DEPT
 Primary Lab MA Cert #: M-MA022 Primary Lab Name: ANALYTICAL BALANCE CORP

PWS Class: COM

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10383	925 CIRCUIT ST - FIRE STATION #3	RS	W. MILLS	6/10/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		146807101

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	11.0	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	11.3	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	10.3	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	13.6	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	46.2	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10387	2055 WASHINGTON ST - COMPUTER CENTER	RS	W. MILLS	6/10/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		146807102

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	31.3	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	2.8	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	29.5	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	20.6	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	84.2	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10388	33 ROCKLAND ST - HANOVER FITNESS	RS	W. MILLS	6/10/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		146807103

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	11.0	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000
 PWS Name: HANOVER WATER DEPT

6/27/2014 12:01:43 PM
 Page 1 of 2

Trihalomethane Report

Data Check - Unsigned

BROMOFORM	0.9	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	22.8	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	5.6	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	40.3	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 665029

M/S = Multiple or Single sources represented in sample site.

D/S = Distribution or Source sample site.

R/F = Raw or Finished water sample site.

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

6/27/2014 12:01:43 PM

Page 2 of 2

Trihalomethane Report

Data Check - Unsigned

PWS ID #: 4122000 City/Town: HANOVER
 PWS Name: HANOVER WATER DEPT
 Primary Lab MA Cert #: M-MA022 Primary Lab Name: ANALYTICAL BALANCE CORP

PWS Class: COM

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10385	70 PONDEROSA	RS	W. MILLS	6/17/2014	O		
Sample Comments:		Analysis Comments:		Lab Sample ID:			
				146827401			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	27.5	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	4.2	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	26.4	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	19.9	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	78.0	UG/L	0.5	EPA 524.2	6/17/2014	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 668350

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

Trihalomethane Report

Submitted - Signed

PWS ID #: 4122000 City/Town: HANOVER
 PWS Name: HANOVER WATER DEPT
 Primary Lab MA Cert #: M-MA022 Primary Lab Name: ANALYTICAL BALANCE CORP

PWS Class: COM

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10383	925 CIRCUIT ST - FIRE STATION #3	RS	W. MILLS	9/23/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		147144401

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	15.8	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	7.4	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	15.2	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	14.9	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	53.3	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10385	70 PONDEROSA	RS	W. MILLS	9/23/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		147144402

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	24.0	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	6.6	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	19.4	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	23.4	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	73.4	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10388	33 ROCKLAND ST - HANOVER FITNESS	RS	W. MILLS	9/23/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		147144403

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	18.0	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	ND	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000
 PWS Name: HANOVER WATER DEPT

10/9/2014 7:56:37 AM
 Page 1 of 2

Trihalomethane Report

Submitted - Signed

CHLOROFORM	57.2	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	5.3	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	80.5	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10387	2055 WASHINGTON ST - COMPUTER CENTER	RS	W. MILLS	9/23/2014	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

147144404

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	13.1	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	6.6	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	10.4	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	14.4	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	44.5	UG/L	0.5	EPA 524.2	9/25/2014	M-MA022	ANALYTICAL BALANCE CORP

Primary Lab Signature: Robert Bentley

Date: 10/9/2014

Certified Signer User Name: ANALYTICAL

EDEP Transaction ID: 692091

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

Trihalomethane Report

Data Check - Unsigned

PWS ID #: 4122000 City/Town: HANOVER
 PWS Name: HANOVER WATER DEPT
 Primary Lab MA Cert #: M-MA022 Primary Lab Name: ANALYTICAL BALANCE CORP

PWS Class: COM

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10383	925 CIRCUIT ST - FIRE STATION #3	RS	W. MILLS	12/30/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		147377401

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	21.7	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	3.3	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	33.4	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	14.0	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	72.4	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10385	70 PONDEROSA	RS	W. MILLS	12/30/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		147377402

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	27.3	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	2.7	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	40.4	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	15.9	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	86.3	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10388	33 ROCKLAND ST - HANOVER FITNESS	RS	W. MILLS	12/30/2014	O		

Sample Comments:	Analysis Comments:	Lab Sample ID:
		147377403

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	16.3	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	2.2	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000
 PWS Name: HANOVER WATER DEPT

1/20/2015 9:08:24 AM
 Page 1 of 2

Trihalomethane Report

Data Check - Unsigned

CHLOROFORM	26.8	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	11.7	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	57.0	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
10387	2055 WASHINGTON ST - COMPUTER CENTER	RS	W. MILLS	12/30/2014	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

147377404

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
BROMODICHLOROMETHANE	24.5	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
BROMOFORM	1.7	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
CHLOROFORM	39.1	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
DIBROMOCHLOROMETHANE	12.4	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP
TOTAL TRIHALOMETHANES	77.7	UG/L	0.5	EPA 524.2	12/31/2014	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 715634

M/S = Multiple or Single sources represented in sample site.
 D/S = Distribution or Source sample site.
 R/F = Raw or Finished water sample site.
 MDL = Method Detection Limit.
 UOM = Unit of Measurement.
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000
 PWS Name: HANOVER WATER DEPT

1/20/2015 9:08:24 AM
 Page 2 of 2